

CONCEALED SLIDE ARM DOOR CLOSERS

ITS.11204







CONCEALED SLIDE ARM DOOR CLOSERS

ITS.11204

Renowned for its slimline mechanism (32mm body) and suitability for assisting BS8300 requirements, the Rutland ITS.11204 Cam Action door closer has been successfully fire tested numerous times in 44mm fire doors, making it a perfect door closer for situations where minimal aesthetics are required.







Certification

110°

Speed Regulation







Guarantee

Max Door Width

Max Door Weight

- Certifire Approved
- Power Adjustable by spring, size 2-4
- Suitable for both 44 and 54mm thick doors
- Available in Silver, Satin Nickel, Polished Nickel, Polished Brass & Antique Brass for next day delivery



Finishes		See page 98 for more detail		
0				
SE	SNP	PNP	PVD	АВ
Silver	Satin Nickel	Polished Nickel	Polished Brass	Antique Brass














Product Features	ITS.11204
Delayed Action	-
Back Check	-
Opening Angle	110°
Fig.1 Pull Side Door Width	595-1100mm
Fig.66 Push Side Door Width	595-1100mm
Fig.1 BS8300 Min Door Width	835mm
Max Door Weight	<130kg
Power Adjustment	By Spring
Hold Open (not for fire doors)	0
Dimensions	W243 x H52 x D32mn
Certification Compliance	
Certifire	✓
UKCA	✓
CE	✓
BS EN 1154	✓
BS EN 1634	✓
UL10C	-
UL228	✓
ANSI BHMA	-
IFCC	✓
Key: ✓ Yes - No • Optio	ın .



Description		EN Size	Finish		Re-order Code	Product Code	Box Qty
ITS.11204							
			Silver		11172	ITS.11204.2.5.SE	10
			Satin Nickel		11173	ITS.11204.2.5.SNP	10
	Single Action-ITS.11204		Polished Nickel		11170	ITS.11204.2.5.PNP	10
3	concealed standard rail slide	2-4	Polished Brass		11171	ITS.11204.2.5.PVD	10
	arm door closer		Antique Brass		12026	ITS.11204.2.5.AB	10
			Satin Brass	-	12521	ITS.11204.2.5.SB	10
			Black		12199	ITS.11204.2.5.BK	10
	ITS.11204 Mechanism only	2-4	Silver		11165	ITS.11204	10
	TT 44004		Silver		12001	SA.2.5.SE	25
	ITS.11204 concealed door closer-to-slide arm complete		Satin Nickel		12002	SA.2.5.SNP	25
	with single action connector bar - CB.5	_	Polished Nickel		11998	SA.2.5.PNP	25
	טמו - כט.ט		Polished Brass		11999	SA.2.5.PVD	25
	Standard Rail Intumescent Pack	-	-		11161	IP.114	100

t. +44 (0)1246 261491 | e. sales@rutlanduk.co.uk

CERTIFICATE OF APPROVAL No CF5902

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

RUTLAND UK

Whittington Way, Chesterfield, SA1 9AG TEL: 01246 261491

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT ITS.11204 Concealed Door Closers TECHNICAL SCHEDULE
TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan

Certification Manager



Issued: Audit Test Frequency: Valid to:



CERTIFICATE No CF5902 RUTLAND UK

ITS.11204 Concealed Overhead Closer

1. This approval relates to the following concealed overhead door closing device and configurations:

	ITS.11204
Single-action	✓
Double-action	×
Body door mounted in top edge	y,
Body transom mounted	×

Key:

✓ - approved

Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

- 2. This certification is provided to the client for its own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. This approval relates to their use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 60 minutes (Code ITT).

- 4. The closers are approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1
 - ii) An appraisal against TS34
 - iii) Certification of quality management system.
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with EN 1154 requirements
- 5. The closers shall be fixed with screws supplied by the closer manufacturer.
- 6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.

Signed Page 2 of 7 J/150

Pel ligge

Issued: 6th

CERTIFICATE No CF5902 RUTLAND UK

ITS.11204 Concealed Overhead Closer

- Concealed closers shall only be fitted to doorsets which have previously been shown capable of accommodating the installation of similar concealed items at the head of the doorset, without detriment to the doorset's performance.
- 8. This approval is applicable only to the specified concealed closers used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154). Concealed closer models shall only be installed in conjunction with the intumescent protection detailed below.
- 9. This approval relates to ITS.11204 concealed overhead closers used with latched or unlatched single-leaf or double-leaf, assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores and in timber frames:
 - a. <u>ITT30</u> The bodies mounted in the door leaf, are approved for 30 minute single-action doorsets of the following specification (Code ITT):
 - i. Door leaves shall not less than 44 mm thick doors.
 - ii. The door frame shall consist of softwood or hardwood with a minimum density of 510 kg/m³ and with a minimum thickness of 30 mm (excluding any stop).
 - iii. The closer body was mounted centrally within the door thickness and the guiderail centrally within the frame rebate.
 - v. The closer shall be fitted with intumescent protection in the form:
 - 2 mm thickness of graphite-based intumescent sheet material (ref. IP.114), over the entire forend and recess in the top edge of the door.
 - 2 mm thickness of graphite-based intumescent sheet material (ref. IP.114), to the vertical edges only of the guiderail.
 - b. <u>ITT60</u> The bodies mounted in the door leaf, are approved for 60 minute single-action doorsets of the following specification (Code ITT):
 - i. Door leaves shall not less than 54 mm thick doors.
 - ii. The door frame shall consist of hardwood with a minimum density of 640 kg/m³ and with a minimum thickness of 44 mm (excluding any stop).
 - iii. The closer body was mounted centrally within the door thickness and the quiderail centrally within the frame rebate.

Signed Page 3 of 7 J/150


Pel Ragon


Issued: 6th S Valid to: 5th S


CERTIFICATE No CF5902 RUTLAND UK

ITS.11204 Concealed Overhead Closer

- iv. The closer shall be fitted with intumescent protection in the form of:
 - 2 mm thickness of graphite-based intumescent sheet material (ref. IP.114), over the entire forend and recess in the top edge of the door.
 - 2 mm thickness of graphite-based intumescent sheet material (ref. IP.114), to the vertical edges only of the guiderail.
- v. In addition for ITT60 applications the perimeter intumescent fire seals within the door or frame shall by-pass the guide rail by a minimum of 3 mm on each side.







Note: Failure to install intumescent protection identified above will invalidate this certificate

10. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed Page 4 of 7 J/150

Pel agg-

Issued: Valid to:

CERTIFICATE No CF5902 RUTLAND UK

ITS.11204 Concealed Overhead Closer

The following table shows acceptable doorset types and fire resistance periods for the concealed closer:

* ,		Арр	roved Door	Туре	ā
Class	IMM	IVIIVI	ITT	ITM	ITC
FD20	ж	x	✓	x	x
FD30	ж	x	✓	x	x
FD60	ж	*	✓	x	x
FD120	x	x	x	x	x
FD240	x	x	x	x	ж
E 20	x	x	✓	x	ж
EI 20	x	x	✓	×	*
E 30	x	sc	✓	ж .	×
EI 30	x	x	✓	ж	×
E 60	x	x	✓	ж	×
EI 60	x	x	✓	ж	×
E 90	x	x	×	ж	×
EI 90	x	sc	x	×	×
E 120	x	SC	30	ж	×
EI 120	·)c	x	x	×	×
E 240	x	sc	x	×	×
EI 240	×	ж	x	ж	x

- approved

- Not approved

Signed Page 5 of 7 J/150

Pel agg-

Issued:

CERTIFICATE No CF5902 RUTLAND UK

ITS.11204 Concealed Overhead Closer

12. Doors are classified as the following types:

Code ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in timber-based frames.

Code ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in steel frames.

Code ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Code MM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Scope of Approval:

- The closer may not be fitted to timber doorsets without perimeter intumescent fire seals within the frame rebate or door edge.
- Concealed overhead closers and their guide channel shall only be fitted in conjunction with the intumescent protection detailed previously in this certificate.
- Concealed overhead closers shall only be fitted to doorsets which have previously been shown capable of accommodating the installation of similar concealed items at the head of the doorset, without detriment to the doorset's performance.
- Mechanical Hold open option is not approved
- The following specific guide channels are approved for use with the concealed closers:
 - Non-hold open single-action guiderail with lever arm 29 mm wide x 19 mm high x 460 mm long.
- The following functions are supported by this certification:

Closer Ref.	Latch Control	Backcheck	Delayed-Action
ITS.11204	✓	×	x

Signed Page 6 of 7 J/150

Pel agg-

Issued: Valid to:

CERTIFICATE No CF5902 RUTLAND UK

ITS.11204 Concealed Overhead Closer

Classification code

ITS.11204:

3 8	4 2	1	1	3
-----	-----	---	---	---

Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Further Information

Further information regarding the details contained in this certificate may be obtained from Rutland UK. (Tel: 01246 261491).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed Page 7 of 7 J/150

Pel Agg-

Issued: Valid to:

certification

CONTROLLED DOOR CLOSER DEVICES

Certificate number: IFCC 1417

This is a product certificate to certify that

RUTLAND UK

Whittington Way, Chesterfield S41 9AG UK Telephone no. 01246 261491

Who fabricate the following concealed Door Closers:

ITS.11204

have satisfied the requirements of the SDP08 Controlled Door Closer scheme. This includes the testing of products to EN 1634-1, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production.



First Issued: 24 Jan 2019 Revised: 18 Oct 2022 Valid to: 23 Sept 2024 Issue No: 2



175

Ian Woodhouse Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd 220111 F27b

Page 1 of 3



Rutland ITS.11204 Concealed Overhead Door Closer

Acceptable doorset types and fire resistance periods are identified in the table below:-

	Approved Door Types							
FR	IMM	MM	П	ITT	ITM	ITC		
FD20	\checkmark	√	Х	√	Х	Х		
FD30	√	√	Х	√	Х	Х		
FD60	√	√	Х	√	Х	Х		
FD90	√	√ .	Х	Х	Х	X		
FD120	√	√	Х	Х	Х	Х		
FD240	√	√	Х	Х	X	X		
E20	√	√	Х	√	Х	X		
EI20	√	√	Х	√	Х	X		
E30	\checkmark	√	Х	√	Х	X		
EI30	√	√	Х	√	Х	X		
E60	√	√	X	√	X	X		
EI60	√	√	X	√	X	X		
E90	\checkmark	√	Х	Х	Х	Х		
EI90	\checkmark	√	X	Х	Х	X		
E120	√	√	X	X	X	X		
EI120	v	√	X	X	X	X		
E240	√	√	X	X	X	X		
EI240	√	√	X	X	Х	Х		

Key

Type TT - 20 minute doorsets that consist of non-metallic leaves in timber frames that do not contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27b ©IFC Certification Ltd 220111

Page 2 of 3



Classification

Category of use	Durability	Power Level	Fire	Safety	Corrosion Rating
3	8	2/4	1	1	3

This approval only relates to its use with the door assemblies and configurations identified in **PAR/11364/01 Rev B** and Fire Test Evidence **CFR2501191 & CFR2109081**;-

ITT Timber Leaf & Timber Frame

May be fitted in previously tested single and double-acting, latched or unlatched, intumescent sealed timber door and timber frame assemblies.

IMM & MM Steel Leaf & Steel Frame

May be fitted in previously tested single-acting steel door assemblies, if required in latched or unlatched un-insulating or insulating steel door leaf and steel frame assemblies.

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.


F27b ©IFC Certification Ltd 220111

Page 3 of 3

Hold Open Device

FOR NON-FIRE DOOR APPLICATION









SLIDE ARM

Cushion Stop Installation




Step 1 Slide the cushion (2) into the rail (1) up against the stop.



Step 2

Insert the white shuttle (3) and continue fixing the closer and connecting the rail (1).



Maintenance





Check that screws are tight (No.1 & No.2), and tighten if needed, at least every 6 months.



Tighten pinion screw (No. 3) to 12nm, at least every 6 months




Lubricate all moving parts, except the sliding shuttle (No.4), at least every 6 months.

Any unusual sounds or visual defects should be addressed immediately

^{*}For high usage closers, this steps will need to be carried out more often than every 6 months.



Valve Adjustments



Before adjusting any valves ensure the door and frame are fixed firmly and the door will close easily into the frame and latch.

- To increase the speed of a door turn the valve 1 (No.5) Anti-clockwise. If door closing too fast turn the valve 1 Clockwise to reduce the speed to a satisfactory movement.
- When the door is latching too fast adjust the valve 2 (No. 6) to the desired satisfactory action. Turn Clockwise to reduce the speed.
- If the latch is getting stuck, turn Valve 2 anti-clockwise to increase the speed but not too fast so that it slams.
- If more power is needed to overcome the latch or Intumescent seal you can increase the power by turning the power adjustment function (No. 7) with an allen key.
- If the door is too easy to open or affected by wind or air pressure, turn Clockwise to increase the power.
- If the door is stiff to open you can turn Anti-clockwise to decrease the power.

Back Check + Delayed Action on Slide Arm closers

- If the door hits a wall when fully opened you can adjust the Back Check valve. Turn valve Clockwise with a screw driver to increase the Back Check facility. This will slow the door down on opening at speed. Back Check valve if applicable to this model.
- If a delay or extra time is required on the closing of the door, the Delayed Action valve can be used. Turn the valve clockwise if more time is required or turn the valve anti-clockwise if less time is required. Delayed Action valve if applicable to this model.

Enhancing life safety at every fire door

